

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3550-0450:004 Page 1 of 1

**CATEGORY:** Door Closers/Holders/Releasing Devices

**LISTEE:** LCN Closers, 121 Railroad Ave., Princeton, IL 61356  
Contact: Rex Lasson (815) 875-3311

**DESIGN:** SENTRONIC Models 4013SEC, 4014SEC, 4113SEC, 4114SEC, 4013SED, 4014SED, 4113SED, 4114SED, 4013SEDS, 4014SEDS, 4113SEDH and 4114SEDH. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as door closers/holders with integral smoke detection for use with separately listed fire alarm control unit. Unit with ionization fire detector may be used in lieu of conventional holder with fusible link arrangement.



---

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 2, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy  
Program Manager